

# Limit and Enclosed Switches

## Reference Standards

### MICRO SWITCH ENCLOSURES IN THIS CATALOG

	NEMA TYPES													
	Non-Hazardous Locations								Hazardous Locations					
	1	3	4	4X	6	6P	12	13	7B	7C	7D	9E	9F	9G
HDLS*	●	●	●	● <sup>9</sup>	●	● <sup>10</sup>		●						
LS	●	●	●		●			●						
E6/V6	●													
BZG/BZH	●	● <sup>3</sup>	● <sub>3</sub>					● <sup>3</sup>						
BAF1	●	● <sup>2</sup>	● <sub>2</sub>					● <sup>2</sup>						
OP	●	● <sup>3</sup>	● <sub>3</sub>					● <sup>3</sup>						
914CE	●	●	● <sup>4</sup>		● <sup>4</sup>	● <sup>4</sup>	● <sup>4</sup>	● <sup>4</sup>						
LN	●	●	●					●						
LSX	●	●	●		●			●	●	●	●	●	●	●
EX	●								● <sup>5</sup>	●	●	●	●	●
CX	●	●	●	● <sup>6</sup>				●	● <sup>7</sup>	●	●	●	●	●
BF	●	●	●					●						
CLS	●	●	●					●						
2CLS	●	●	●					●						
CLSX	●	●	●					●	●	●	●	●	●	●

Note 2 — Not applicable to BAF-1-2RQ9 listings.

Note 3 — Not applicable to Q-plunger types.

Note 4 — 914CE1, 914CE2, and 914CE3 listings comply with NEMA 1 and 3 only.

Note 5 — Only EX series 800, EXD, EXH, and EXN.

Note 6 — Only CX series 80.

Note 7 — Only listings with HS or DT basic switches.

Note 8 — Not applicable to LZ side lever types.

Note 9 — Stainless steel LS2.

Note 10 — Pre-wired HDLS.

### APPLICATION INFORMATION

